

Table 2  
ASTM G155 Standard Practice for Operating Xenon Arc Light Apparatus for  
Exposure of Non-Metallic Materials Test Results

<b>Specimen Number</b>	<b>Observations</b>
1	No cracking, checking, crazing, erosion or other deleterious effects were observed after 2000 hours of exposure.
2	No cracking, checking, crazing, erosion or other deleterious effects were observed after 2000 hours of exposure.
3	No cracking, checking, crazing, erosion or other deleterious effects were observed after 2000 hours of exposure.
4	No cracking, checking, crazing, erosion or other deleterious effects were observed after 2000 hours of exposure.
5	No cracking, checking, crazing, erosion or other deleterious effects were observed after 2000 hours of exposure.